

Experimental Implementation of the Mp-GM (Maximum peak – Gain Margin) Tuning Method

A Tuning Method for 2DOF-IMC under uncertainty process

Juwari, S.Y. Chin, B.B. Abdul Aziz


Faculty of Chemical Engineering and Natural Resources
Universiti Malaysia Pahang
Kuantan, Malaysia

Rosbi Mamat

Faculty of Electrical Engineering
Universiti Teknologi Malaysia
Johor Bahru, Malaysia

Abstract— Internal Model Control (IMC) yields very good performance for set point tracking, but gives sluggish response for disturbance rejection problem. A two-degree-of-freedom IMC (2DOF-IMC) has been developed to overcome the weakness. However, the setting of parameter becomes a complicated matter if there is an uncertainty model. The present study implements a new tuning method for the controller. The proposed tuning method consists of three steps: Firstly, determine the worst case of the model uncertainty. Secondly, specify the parameter of set point controller using maximum peak (Mp) criteria. And finally, obtain the parameter of the disturbance rejection controller using gain margin (GM) criteria. The method is denoted as Mp-

View metadata, citation and similar papers at core.ac.uk

brought to you by  **CORE**

provided by UMP Institutional Repository

the present study, evaluation and comparison have been done through the experimental test rig of the air heater system. Although, the air heater process has two regions that are very different characteristic, the Mp-GM tuning method are able to obtain the good controller parameter even under process uncertainties.

Keywords—Tuning 2DOF-IMC; Mp-GM Tuning; IMCTUNE; Model Uncertainty